

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/22/2021	
Samples Taken By:	Tim LeVan	
Samples Taken By:	Jack Thomas	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Lansinburgh High School
BLDG ADDRESS:	320 Seventh Ave Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/22/2021	Lead test Results ug/L from	Remediation
138	LHS-02-CF-P-138	245 Faculty room	Sink faucet	Delta	1965	X	6:08	3.7		
139	LHS-02-DW-P-139	Corridor outside 242	Water fountain	Halsey Taylor	1965	X	6:09	<1.0		
140	LHS-02-DW-P-140	Corridor outside 250	Water fountain	Elkay	1965	X	6:10	3.1		
141	LHS-02-DW-P-141	Corridor outside 251	Water fountain	Halsey Taylor	1965	X	6:11	<1.0		
142	LHS-02-CF1-P-142	260	Sink faucet 1	Kohler	1965	X	6:12	<1.0		
143	LHS-02-CF2-P-143	260	Sink faucet 2	Kohler	1965	X	6:12	<1.0		
144	LHS-02-BF-P-144	Boys room across from 260	Sink faucet	Chicago	1965	X	6:14	<1.0		
145	LHS-02-BF-P-145	Faculty bathroom across from 260	Sink faucet	Chicago	1965	X	6:15	<1.0		
146	LHS-02-BF1-P-146	Girls room next to stairwell	Sink faucet 1		2007	X	6:16	2.1		
147	LHS-02-BF1-P-147	Girls room next to stairwell	Sink faucet 2		2007	X	6:16	1.8		
148	LHS-02-BF1-P-148	Girls room next to stairwell	Sink faucet 3		2007	X				Removed, No Sample

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy NY 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/22/2021
Samples Taken By:	Tim LeVan
Samples Taken By:	Jack Thomas

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Lansingburgh High School
BLDG ADDRESS:	320 Seventh Ave Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1965	2007			

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/22/2021	Lead test Results ug/L from	Remediation
75	LHS-GF-DW-P-75	Cafeteria	Water fountain	Elkay		X	4:55	<1.0		
76	LHS-GF-DW-P-76	Cafeteria	Bottle filler	Elkay		X	4:55	<1.0		
77	LHS-GF-CF-P-77	Cafeteria	Sink faucet	Delta	2015	X	4:57	4.4		
78	LHS-GF-BF-P-78	Boys room	Sink Faucet	Chicago	1965	X	4:58	<1.0		
79	LHS-GF-BF-P-79	Girls room	Sink faucet	Chicago	1965	X	4:58	<1.0		
80	LHS-GF-CF-P-80	Auto shop	Sink faucet	Speakman	1965	X	5:00	7.3		
81	LHS-GF-CF-P-81	Wood shop	Sink faucet		1965	X	5:02	18.1		Turned off for repair
82	LHS-GF-DW-P-82	Corridor by locker rooms	Water fountain	Halsey Taylor	1965	X	5:03	<1.0		
83	LHS-GF-BF-P-83	Girls PE coach office bathroom	Sink faucet	Kohler	2007	X	5:04	5.4		
84	LHS-GF-GIM-P-84	Girls PE coach office bathroom	Ice Machine	Marvel Scientific	2007	X	7:58	<1.0		
85	LHS-GF-BF-P-85	Girls locker room	Sink faucet	Chicago	2007	X	5:05	9.6		
86	LHS-GF-DW-P-86	Girls locker room	Water fountain		2007	X	5:06	4.2		
87	LHS-GF-BF-P-87	Boys PE coach office bathroom	Sink faucet	Kohler	2007	X	5:08	<1.0		
88	LHS-GF-BIM-P-88	Boys PE coach office bathroom	Ice Machine	Marvel Scientific	2007	X	8:00	<1.0		
89	LHS-GF-BF-P-89	Boys locker room	Sink faucet	Chicago	2007	X	5:08	10		
90	LHS-GF-DW-P-90	Weight room	Water fountain	Elkay	2007	X	5:10	6.7		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/22/2021
Samples Taken By:	Tim LeVan
Samples Taken By:	Jack Thomas

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Lansingburgh High School
BLDG ADDRESS:	320 Seventh Ave Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/22/2021	Lead test Results ug/L from	Remediation
91	LHS-GF-HC-P-91	Outdoors of weight room	Hose connection		2007	X	5:12	37		Turned off for repair
92	LHS-GF-KF-P-92	Outside concession stand	Sink Faucet		2007	X	5:14	6.7		
93	LHS-GF-DW1-P-93	Gym lobby	ADA water fountain	Elkay	2007	X	5:16	<1.0		
94	LHS-GF-DW2-P-94	Gym Lobby	Water fountain	Elkay	2007	X	5:16	<1.0		
95	LHS-GF-KF-P-95	Inside concession stand	Sink faucet	Moan	2007	X	5:17	1.4		
96	LHS-GF-BF-P-96	Girls room	Sink faucet	Chicago	2007	X	5:18	<1.0		
97	LHS-GF-BF-P-97	Boys room	Sink faucet	Chicago	2007	X	5:20	<1.0		
98	LHS-GF-BF1-P-98	Girls room off gym	Sink faucet 1	Chicago	2007	X	5:23	<1.0		
99	LHS-GF-BF2-P-99	Girls room off gym	Sink faucet 2	Chicago	2007	X	5:23	<1.0		
100	LHS-GF-BF1-P-100	Boys room off gym	Sink faucet 1	Chicago	2007	X	5:25	<1.0		
101	LHS-GF-BF2-P-101	Boys room off gym	Sink faucet 2	Chicago	2007	X	5:25	<1.0		
102	LHS-GF-HC-P-102	Outdoors Northeast end of gym	Hose connection		2007	X	5:30	6.7		
103	LHS-GF-BF-P-103	Athletic director office bathroom	Sink faucet	Chicago	2007	X	5:28	3.2		
104	LHS-GF-IM-P-104	Athletic director office bathroom	Ice machine	Manitowoc	2007	X	8:02	<1.0		
105	LHS-GF-HC-P-105	Outdoors of boys room	Hose connection		2007		5:32	28.2		Turned off for repair
106	LHS-01-BF-P-106	Music wing faculty ladies room	Sink faucet 1		1965	X	5:36	8.8		
107	LHS-01-BF-P-107	Music wing faculty ladies room	Sink faucet 2		1965		5:36	6.1		
108	LHS-01-BF-P-108	Music wing boys room	Sink faucet 1		1965	X	5:38	6.6		
109	LHS-01-BF-P-109	Music wing boys room	Sink faucet 2	Kohler	1965	X	5:38	5.5		
110	LHS-01-DW-P-110	Corridor near 185	Water fountain			X	5:39	1.5		
111	LHS-01-BF1-P-111	Girls room near 156	Sink faucet 1	Chicago	1965	X	5:41	<1.0		
112	LHS-01-BF2-P-112	Girls room near 156	Sink faucet 2	Chicago	1965	X	5:41	<1.0		
113	LHS-01-BF1-P-113	Boys room near 156	Sink faucet 1	Chicago	1965	X	5:42	<1.0		
114	LHS-01-BF2-P-114	Boys room near 156	Sink faucet 2	Chicago	1965	X	5:42	<1.0		
115	LHS-01-DW-P-115	Corridor across from 152	Water fountain	Haley Taylor	1965	X	5:43	<1.0		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/22/2021	
Samples Taken By:	Tim LeVan	
Samples Taken By:	Jack Thomas	

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Lansingburgh High School
BLDG ADDRESS:	320 Seventh Ave Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/22/2021	Lead test Results ug/L from	Remediation
116	LHS-01-CF1-P-116	147	Sink faucet 1	T&S	1965	X	5:46	<1.0		
117	LHS-01-CF2-P-117	147	Sink faucet 2		1965	X	5:46	<1.0		
118	LHS-01-CF3-P-118	147	Sink faucet 3	T&S	1965	X	5:46	1.6		
119	LHS-01-DW-P-119	Corridor across from 147	Water fountain	Elkay		X	5:48	<1.0		
120	LHS-01-DW-P-120	Corridor across from 147	Bottle filler			X	5:48	<1.0		
121	LHS-01-BF1-P-121	Boys room	Sink faucet 1		1965	X	5:50	52.8		Turned off for repair
122	LHS-01-BF2-P-122	Boys room	Sink faucet 2		1965	X	5:50	1.2		
123	LHS-01-BF1-P-123	Girls room	Sink faucet 1		1965	X	5:52	2.6		
124	LHS-01-BF2-P-124	Girls room	Sink faucet 2		1965	X	5:52	6		
125	LHS-01-BF3-P-125	Girls room	Sink faucet 3		1965	X	5:52	3.5		
126	LHS-01-BF4-P-126	Girls room	Sink faucet 4		1965	X	5:52	1.4		
127	LHS-01-DW-P-127	Corridor outside 142	Water fountain	Halsey Taylor	1965	X	5:55	<1.0		
128	LHS-01-BF-P-128	Media center bathroom	Sink faucet	Chicago		X	5:59	<1.0		
129	LHS-01-SF-P-129	Media center office	Sink faucet			X	5:59	<1.0		
130	LHS-01-DW-P-130	Corridor across from 1st floor media center	Water fountain	Elkay		X	5:59	<1.0		
131	LHS-02-DW-P-131	Corridor across from 2nd floor media center	Water fountain	Elkay		X	6:02	<1.0		
132	LHS-02-BF-P-132	Media center 2nd floor bathroom	Sink faucet	Chicago		X	6:03	<1.0		
133	LHS-02-BF1-P-133	Boys room across from 248	Sink faucet 1		1965	X	6:05	2.5		
134	LHS-02-BF2-P-134	Boys room across from 248	Sink faucet 2		1965	X	6:05	2.6		
135	LHS-02-BF3-P-135	Boys room across from 248	Sink faucet 3		1965	X				Removed, No Test
136	LHS-02-BF-P-136	Faculty men's room	Sink faucet		1965	X	6:07	1.7		
137	LHS-02-BF-P-137	Faculty women's room	Sink faucet		1965	X	6:07	7.4		

Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	